



DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE.  
CONSULT FACTORY FOR CERTIFIED DRAWINGS.

CAPACITIES-OUTPUT	
HORSEPOWER	— 20
LBS./HR. STEAM	— 690
KG./HR. STEAM	— 313
BTU/HR. X 1000	— 670.
KCAL/HR. X 1000	— 169.
INPUT REQUIRED	
BTU/HR. X 1000	— 837
KCAL/HR. X 1000	— 211
CONNECTION SIZES	
A	1" STEAM OUTLET
B	1" SPARE
C	1 1/2" INSPECTION
D	1" FOR PROBE TYPE 2nd
E	LOW WATER CUT-OFF
F	SAFETY VALVE, 1" OUTLET (1" CPLG.)
F	1" BLOWDOWN VALVE
G	3/4" FEEDWATER LINE
H	WATER CAP. AT NWL — 54 GAL.
I	WATER CAP. FLOODED — 79 GAL.
J	SHIPPING WEIGHT 2450 LBS.

**HURST BOILER & WELDING CO., INC.**  
P.O. DRAWER 529, HIGHWAY 319 S., COOLIDGE, GA. 31738  
PHONE: 912-346-3545 FAX: 912-346-3874

**20 HP-4 PASS VERTICAL TUBELESS BOILER WITH 30 GAL. BOILER FEEDWATER SYSTEM & 8" DIA. X 26" BLOWDOWN SEPARATOR**  
150 PSI DESIGN PRESSURE

R	BY:	DATE:	CHK'D:	REASON FOR CHANGE

SCALE:	DMN. BY:	DATE:	CHK'D. BY:	DRAWING NO.:
NTS 24	MB	10-26-99	JHO	447-20-150RB

THIS DRAWING IS THE PROPERTY OF HURST BOILER AND WELDING CO., INC. AND MAY NOT BE COPIED OR REPRODUCED IN ANY WAY UNLESS AUTHORIZED IN WRITING BY HURST BOILER AND WELDING CO., INC. AND MUST BE RETURNED UPON REQUEST.